

Addendum

Project: CBH Hospital
24211 Forty Four Lane
Harris County, Texas 77447

Project No: 080241

Addendum No: 003

Date: January 4, 2019

The following is an Addendum and is hereby incorporated into the Construction Documents dated November 16, 2018.

- I. Revised toilet/flush valve/accessory part numbers, changes underlined, thus:
 - A. Changed standard WC-1 to top spud with ligature-resistant accessory: ASETF-1490-FM-FA-10-TS-1.28-GWC-TW4-FV1.28-ASFVC-DC-AP
 - B. Changed handicapped WC-1 to handicapped height with top spud and ligature-resistant accessory, one each at rooms: N104, N106, NA111, NB111, NC111, ND111 (six total): ASETF-1490-FM-FA-10-TS-HC-1.28-GWC-TW4-FV1.28-ASFVCADA-DC-AP
- II. Change WC fixtures to different fixture call at the following rooms:
 - A. HCT LB104: Change from WC-2 to WC-1 handicapped.
 - B. Girls N104: Change HC stall from WC-2 to WC-1 handicapped (included in I.B. above). Change standard stall from WC-3 to WC-1. Delete WC-3 from Plumbing Fixture Schedule.
 - C. Boys N106: Change HC stall from WC-2 to WC-1 handicapped (included in I.B. above).

Attachments:
None

This concludes Addendum No. 003