

Addendum

Project: CBH Hospital
24211 Forty Four Lane
Harris County, Texas 77447

Project No: 080241

Addendum No: 004

Date: January 7, 2019

The following is an Addendum and is hereby incorporated into the Construction Documents dated November 16, 2018.

I. Miscellaneous electrical revisions generated by Subcontractor questions to MEP Engineer.

Attachments:

CBH Hospital – MEP Addendum No4 010719.pdf

This concludes Addendum No. 004



PROJECT: CBH Hospital
Landy Commercial Village Section 5
Hockley, Harris County, Texas

ADENDUM No 004: Electrical Miscellaneous Revisions

DATE: January 7, 2019

ELECTRICAL

- SHEET E5.1
 1. Change all (4) Automatic Transfer Switches on this project to 4-Pole in lieu of 3-Pole.

- ELECTRICAL SPECIFICATIONS
SECTION 16231 – PACKAGED ENGINE GENERATOR
 1. Remove the following approved manufacturers:
 - A) Magnatek, Inc.
 - B) Spectrum Detroit Diesel
 2. Add the following manufacturer as approved:
 - A) Taylor Power Systems, Inc.