

BID REQUEST FOR INFORMATION RESPONSE NO. 1

To:	Invited Bidders	Date:	February 8, 2018
Company:		Project Name:	Inpatient Rehab Expansion
Address		Project Number:	17316.00
Phone No:		Fax #:	
From:	Sam Neves	Send via:	<i>e-mail</i>
		Sent:	<i>For your information</i>

This is an R.F.I. Response to questions during the Bidding process before the Bid due date. Information on this Bid R.F.I. Response shall be included in the submitted Bid. Work shall be done in accordance with Contract requirements.

Questions / **Responses:**

1. Sheet E3.01 shows some type of floor box receptacles inside the gym but the documents and specs do not give part numbers or a description of any kind. Please advise.
Response: Floor box shall be equal to Hubbell's 2-gang SystemOne recessed concrete floor rectangular box. Provide flush cover with cable egress doors. Verify and coordinate with slab thickness.
2. Sheet E2.01 keyed note 3 refers us to a semi-private patient room 100. This room is not shown on the electrical plans. Please advise.
Response: The keyed note should read "room 101", not "room 100".

END OF BID REQUEST FOR INFORMATION NO. 1