

ADDENDUM #2, July 10, 2019

A new building for TAMU AgriLife Phenotyping Greenhouse

Project No. 17042

SSC Project No 2017-02185

Notice to all bidders:

This Addendum forms a part of the Contract Documents and modifies the Specifications and Drawings dated **June 24, 2019** to the extent noted hereinafter. All parties of interest shall take careful note of this Addendum so that proper allowance is made in all computations, estimates and contracts and so that all trades affected are fully advised in the performance of work that will be required by them.

A. General:

1. Fire Hydrant manufacturer is "American Darling" with 5" Stortz Connection. (Refer to Drawings and notes on sheets C1, C4, A3.1, P0.1, P2.2, P4.1 included in the drawing set issue for pricing dated June 24, 2019)
2. Use "Shurtape premium grade PW-100 Corrosion Protection Pipe Wrap Tape; plasticized PVC film coating with aggressive rubber based adhesive" for wrapping material at underground PVC pipes. (Refer to Pipe Material Schedule on sheet P0.1 included in the drawing set issued for pricing dated June 24, 2019)
3. For the exterior gas pipe use "Ductile Iron" at underground gas pipes in lieu of galvanized pipe. This material will be in lieu of the material specified on Pipe Material Schedule on sheet P0.1 included in the drawing set issued for pricing dated June 24, 2019)
4. Air louvers and insect screens are specified by Architect and are not provided by Architect. Contractor is responsible for providing louvers and accessories as specified. (Refer to Section 089119 – Fixed Louvers of the specification book issued for pricing dated June 24, 2019. Refer to Addendum #1 dated July 9, 2019 for other acceptable manufacturer.)

B. Specifications:

1. **Section 033000 – Cast-In-Place Concrete:** Barrier-BAC is an acceptable manufacturer for sheet vapor retarder.
2. **Section 26 4113 – Lightning Protection :** Advanced Lightening Technology, Ltd. (ALT) is an acceptable manufacturer for lightning protection system.

END OF ADDENDUM #2



308 N. Bryan Ave.
Bryan, TX 77803
P (979)821-2635
F (979)775-8224
www.arkitex.com



July 10, 2019